



General Assembly

January Session, 2001

Amendment

LCO No. 6066

Offered by:

REP. BOUGHTON, 138th Dist.

To: Subst. House Bill No. 6984

File No. 148

Cal. No. 134

"AN ACT CONCERNING CHANGES TO THE STATE FIRE SAFETY CODE."

1 In line 1, before "(NEW)" insert "Section 1."

2 After line 2, insert the following:

3 "Sec. 2. Subsection (a) of section 29-315 of the general statutes is
4 repealed and the following is substituted in lieu thereof:

5 (a) (1) When any building is to be built having more than four
6 stories and is to be used for human occupancy, such building shall
7 have an automatic fire extinguishing system approved by the State Fire
8 Marshal on each floor.

9 (2) When any building is to be built as an educational occupancy
10 and is put out to bid on or after July 1, 2002, such building shall have
11 an automatic fire extinguishing system approved by the State Fire
12 Marshal on each floor. "Educational occupancy" shall have the same
13 meaning as in the Fire Safety Code."